

STAT

Sanitized Copy Approved for Release 2010/05/17 : CIA-RDP89-00244R001002480048-0

**Page Denied**

Sanitized Copy Approved for Release 2010/05/17 : CIA-RDP89-00244R001002480048-0



October 9, 1985

Centex Construction Company, Inc.  
2947 Gallows Road  
P. O. Box 427  
Merrifield, Virginia 22116

Subject: GS-11B-19066, Bid Package No. 2, Headquarters Building,  
CIA Headquarters Expansion, Langley, Virginia, File 10150-  
Color Selections

Gentlemen:

Reference is made to your letter of October 4, 1985 in connection with the above subject. In order to avoid any unnecessary delay to the project and to resolve this issue of color selection for the toilet partitions, it is requested that you resubmit "submittal 203-18" to the architect as soon as possible and we will instruct the A-E to proceed with the color selection (by way of a copy of this letter). In addition, it is requested that you expedite all other samples and/or finish related items that interface with one another to the architect as soon as possible. This will expedite the review of other submittals and ensure good color coordination of finished work.

Your cooperation in this effort is most appreciated.

Sincerely,

  
Arthur J. Carlucci  
Project Manager  
Headquarters Expansion Project

AJC:nj

cc: Everett Medling  
Gary Lee



STAT



October 9, 1985

Smith, Hinchman & Grylls Associates, Inc.  
455 West Fort Street  
Detroit, Michigan 48226

Attention: W. Everett Medling

Subject: GS-11B-19066, Bid Package No. 2, Headquarters Building,  
CIA Headquarters Expansion, Langley, Virginia, File A5-  
07810, Skylight Transmittal 201-32

Gentlemen:

Please review the attached correspondence and advise as soon as possible  
as to your findings.

Sincerely,

  
Arthur J. Carlucci  
Project Manager  
Headquarters Expansion Project

AJC:nj

Attachment

cc: Garv Lee

STAT

**CENTEX CONSTRUCTION COMPANY, INC.**

POST OFFICE BOX 427 • MERRIFIELD, VA. 22116 • TELEPHONE (703) 698-6886

October 3, 1985

**PLEASE ADDRESS REPLY TO:**

P.O. BOX 6510  
McLEAN, VA 22106-6510  
Phone: (703) 448-6810

Arthur J. Carlucci, Project Manager  
New Building Project Field Office  
Room 3E40, Headquarters Building  
Central Intelligence Agency  
Washington, D.C. 20505

Re: CIA Headquarters Expansion  
Bid Package 2  
Langley, Virginia  
Contract No. GS-11B-19066


Subj: Skylight Transmittal 201-32,  
Rev. B, Specification Section  
07810

Gentlemen:

We have received the approval copy of the subject transmittal with SH&G comments and letter dated September 24, 1985.

Fisher Skylights Inc. notified the architect by means of our notations on drawing 7020 sheet 1 of 2 that sprinkler exit holes at the bottom of the rafters are structurally unacceptable. Attached for your information is a copy of the Fingles Company letter dated September 18, 1985. SH&G comments that they "do not agree" with Fisher's evaluation.

We can follow the direction given by the Architect as per the comments on the drawing. However, we will not accept responsibility for consequences resulting from the "weakened skylight system". Please advise how we are to proceed.



Very truly yours,

CENTEX CONSTRUCTION COMPANY, INC.


*Joseph A. Pius*  
Joseph A. Pius  
Assistant Project Manager

JAP:sap

Enclosure

cc: Merrifield Office  
The Fingles Company  
Transmittal File 201-32

SINCE 1885



OFFICES AND PLANT, 2256 REISTERSTOWN ROAD • BALTIMORE, MARYLAND 21217  
(301) 523-3300

September 18, 1985

Centex Construction Company, Inc.  
Post Office Box 427  
Merrifield, Virginia 22116

Att: Mr. Joseph A. Pius  
Assistant Project Manager

Re: C.I.A. Headquarters Bldg.  
Our Req. #4137

Gentlemen:

In regard to your RFI 144 we have been in touch with Fisher Skylight and have been given the following information.

After going to their engineer they have been told <sup>THAT</sup> to bring sprinkler heads thru the bottom of the rafter bar would weaken the skylight system and it would not meet requirements.

Please advise how to proceed.

Yours very truly,

THE FINGLES COMPANY

  
Bruce D. Anthony

BDA/sms